



RNN 4x12 250x610x120
drzwi transparentne z zamkiem

S304 C25	SM325 -230 4Z+1z+1r	SM325 -230 4Z+1z+1r	P312B6 -30-AC
-------------	---------------------------	---------------------------	------------------

A

A

A

J

S302 B25	SM325	S302 B25	SM325	S302 B25	SM325	S302 B25	SM325
-------------	-------	-------------	-------	-------------	-------	-------------	-------

B

C

D

E

LZ2,5x30	S302B6	S302B6	S302B6
----------	--------	--------	--------

F

G

H

FR304 -63A	⊗
---------------	---

$$P_{inst.} = 11,3 \text{ kW}$$

$$\text{dla } k=0,85$$

$$P_{obl.} = 9,6 \text{ kW}$$

$$I_{obl.} = 15,4 \text{ A}$$

TABLICA W POM. TECHNICZNYM

TEMAT	REMONT HALI SPORTOWEJ – SALA GIER ZESPOŁOWYCH Akademia Wychowania Fizycznego, Katowice ul. Mikołowska 72A		
BRANŻA	ELEKTRYCZNA	SKALA	
TREŚĆ	TOS – tablica sali gier	RYS. NR	E2
FAZA	PROJEKT BUDOWLANO–WYKONAWCZY	czerwiec 2017r.	
PROJEKTOWAŁ	Antoni HADASZ upr.bud. b/o 1127/94 UW K-ce Ś.I.I.B. SLK/IE/7372/01		